

Prob 1

A community is expected to reach app of 35000 in 20 yrs. It has  $P_0 = 28000$  with avg. WC =  $16 \times 10^6$  l/d. The existing water treatment plant has a design capacity of 28350 m<sup>3</sup>/d. Assume an arithmetic rate of population growth. Determine in which year the existing plant will reach its design capacity. Assume the plant to be designed on max. daily consumption.

Sol

$$P_t = 35000 \quad K = \frac{35000 - 28000}{20 - 0} = 350 \text{ ppyear}$$

$$P_0 = 28000$$

$$\text{Avg. WC per capita per day} = \frac{16 \times 10^6 \text{ l/d}}{28000 \text{ persons}} = 571.4 \text{ lpcd}$$

$$\text{Max. daily WC} = 1.5 \times 571.4 = 857.14 \text{ lpcd}$$

$$P_t \text{ for water treat plant} = \frac{28350 \times 10^3 \text{ l/d}}{857.1 \text{ lpcd}} = 33075 \text{ persons}$$

$$P_t = P_0 + K(t_f - t_0)$$

$$33075 = 28000 + 350(t_f - t_0)$$

$$t_f - t_0 = 14 \text{ yrs.}$$

## Problem-Design period

- Problem 1 : A small community had a population of 65000 and 85000 in the year of 1995 and 2005 respectively. Assuming a geometric growth rate and an average WC of 300lit/cap/day. Calculate the design flow for the treatment plant and the transmission main from current year. Select an appropriate value for design period.
- Problem 2: The present population of a community is 160000 increasing at a geometric growth rate of 0.043 per yr. The present water requirement of the community are fully met by a number of tube wells installed in the city. The average WC is 350l/c/d using a design period of 15 yrs. Calculate the number of additional tube-wells of 3.4m<sup>3</sup>/min capacity to meet the demand of design period.

Data:

$$P_0 = 160000$$

$$K = 0.043 \text{ per yr.}$$

$$AWC = 350 \text{ l/c/d}$$

$$\text{Design period} = 15 \text{ yrs}$$

$$\text{Additional tube wells} = ?$$

$$\text{Tube well capacity} = 3.4 \text{ m}^3/\text{min}$$

### Solution of Prob. 1

Given:  
 $P_{1995} = 65000 \quad P_{2005} = 85000$

$$P_t = P_0 e^{k_n t}$$

$$85000 = 65000 \times e^{10k}$$

$$K = 0.0268 \text{ persons/yr.}$$

For transmission main design period = 50 yrs (design year = 2017 + 50  
 $= 2067$ )

Treatment plant = 15 yrs (design year = 2017 + 15 = 2032)

$$P_t (\text{transmission main}) = 85000 \times e^{0.0268 \times (2067 - 2005)}$$

$$= 447757 \text{ persons}$$

$$P_t (\text{treatment plant}) = 85000 \times e^{0.0268 \times (2032 - 2005)}$$

$$= 175257 \text{ persons}$$

$$\text{Max. daily WC} = 1.5 \times 300 = 450 \text{ lpcd}$$

$$\text{Capacity for transmission mains} = 447757 \times 450$$

$$= 201490.65 \text{ m}^3/\text{d}$$

$$\text{Capacity for treatment plant} = 175257 \times 450$$

$$= 78865.65 \text{ m}^3/\text{d}$$

$AWC = 300 \text{ lpcd}$   
 Design flow for treatment plant  
 i) transmission main

Prob. 2

Current year = 2017

b.

$$P_t = P_0 e^{k_n t} = 160000 e^{0.043 \times 15} = 304957.92$$

$$\text{Additional population} = 304957.92 - 160000$$

$$= 144957.92$$

$$\text{Total WC} = 350 \times 144957.92$$

$$= 50735272 \text{ l/d}$$

$$= 50735.2 \text{ m}^3/\text{d}$$

$$\text{Tubewell capacity} = 3.4 \times 60 \times 24 = 4896 \text{ m}^3/\text{d}$$

With storage / OHR:

$$\text{MDD} = 1.5 \times 50735.2$$

$$= 76102.9 \text{ m}^3/\text{d}$$

$$\text{Total no. of tubewells} = \frac{76102.9}{4896} \approx 16$$

No OHR / Without storage:

$$\text{PI+F} = 2.25 \times 50735.2 = 114154.4 \text{ m}^3/\text{d}$$

$$\text{Total no. of tubewells} = \frac{114154.4}{4896}$$

$$\approx 24$$